NORTH HOPKINS WATER SUPPLY CORPORATION
2025 ANNUAL DRINKING WATER QUALITY REPORT CONSUMER CONFIDENCE REPORT (CCR)

ANNUAL WATER QUALITY REPORT for the period of January 1, 2025- December 31, 2025.

Public Water System ID Number 1120017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. For more information, contact Leeo Casey Janway, Manager, at 903-945-2619.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al teléfono (903) 945-2619.

Special Notice

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immuno-compromised persons such as those undergoing chemotherapy for cancer, those who have undergone organ transplants, those who are undergoing treatment with steroids, and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800)426-4791.

In 2025, our water department distributed 173,074,207 gallons of water to our customers. North Hopkins Water Supply Corporation purchases pre-treated surface water from the City of Sulphur Springs. Our water comes from Cooper Lake (Jim Chapman Lake) with a back up water supply from Lake Sulphur Springs. Your water is treated using a rigorous multi-step process to treat and disinfect the water to ensure its safety. For more information on water quality, please contact Leeo Casey Janway, Manager of NHWSC, at 903-945-2619.

HOW YOUR WATER IS REGULATED

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. To make sure that your tap water is safe, EPA prescribes regulations that limit the amounts of certain contaminants allowed in water after its treatment, when it is delivered by public

water systems. FDA regulations establish limits for the contaminants in bottled water which must provide the same protection for the public health. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline at (800)426-4791. EPA results are available upon request.

The source of drinking water includes rivers, lakes, streams, ponds, reservoirs, springs and wells. Contaminants that may be present in raw surface water before it is treated, also known as source water, include:

- Microbial contaminants, such as viruses and bacteria, may come from wastewater treatment plants, septic systems, agricultural livestock operations or wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential use.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Public Participation Opportunities

Date: Board Meetings 4th Thursday of the Month

Time: 7:00 p.m.

Place Office - 9364 Texas Highway 19 North
Sulphur Springs, Texas 75482
Phone:903-945-2619

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Information About Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is available by the Texas Commission on Environmental Quality. The information contained in the assessment allows focus on source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: https://www.tceq.texas.gov/gis/swaview.

This information describes the susceptibility and types of constituents that may come into contact with our drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus on our source water protection strategies.

Further details about sources of source water assessments are available in Drinking Water Watch at the following URL: http://dww2.tceq.texas,gov/DWW/

Secondary Constituents

Many constituents (such as calcium, sodium or iron) which are often found in drinking water, can cause taste, color and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These are not causes for health concern. Therefore secondary constituents are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Coliform Bacteria 2025

Year	E. Coli Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest Number of Coliform Positive	Number of E. Coli Positive Results	Violation	Likely Source of contamination
2025	0	2 or more samples in any single month	0	0	Y	Naturally present in the environment.

Note: Type 3A, Analyte: 8000 Revised Total Coliform Rule (RCR) Mon. Period: 05/01/2025-05/31/2025.
Our system failed to collect the appropriate number of samples in May 2025 during our monthly sample testing. This resulted in a Monitoring Routine Violation (Minor RTC). In June 2025, all sample sites were collected. Our official date of compliance was July 3, 2025. Escherichia (E.coli) are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly and people with severely compromised immune systems.

REGULATED CONTAMINANTS

Maximum Residual Disinfectant Level

	Average Level	Min Level	Max Level	MRDL	MRDLG	Units	Source of chemical
2025 Chlorine (chloramines)	2.38	.50	3.97	4.0	4.0	ppm	Water additive used to control microbes.

Radioactive Contaminants -2023

Contaminant	Level	MCL	MCLG	Units	Violation	Likely Source Contamination
Combined Radium 226/228	1.5	5	0	pCi/L	N	Erosion of natural deposits.

Radioactive contaminant testing schedule is once every 6 years.

Lead and Copper

Lead & Copper	Year	Action Level Goal (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	<.050	0/20	mg/L	N	Erosion of natural deposits; leaching from wood preservatives, corrosion of household plumbing systems
Lead	2025	.015	<.005	0/20	mg/L	N	Corrosion of household plumbing systems; erosion of natural deposits

Required Additional Health Information for Lead:
If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800)426-4791 or at http://www.epa.gov/safewater/lead.

Customers can access the lead service line inventory at the office located at 9364 Texas Highway 19 North, Sulphur Springs, Texas 75482.

Disinfection Byproducts

Year	Disinfection by-product	Highest Level	Average	MCL	Units	Violation	Likely Source of Contamination
2025	Chlorite	0.18	0.05	1.00	ppm	N	By-product of drinking water disinfection
2025	Total Haloacetic Acids (HAA5)	29	27	60	ppb	N	By-product of drinking water chlorination
2025	Total Trihalomethanes (TTHM)	43	39	80	ppb	N	By product of drinking water chlorination

*The value in the Highest Level column for HAA5 and TTHM is the highest running annual average of sample results collected at a location over a year.

Turbidity

Year		Level (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
2025	Highest single measurement	1.0 NTU	0.11	N	Soil runoff
2025	Lowest monthly % meeting limit	<0.3 NTU	100%	N	Soil runoff

Information statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. It is monitored because it is a good indicator of water quality and the effectiveness of the filtration system and disinfectants.

Synthetic Organic Contaminants

Year	Contaminant	Level Detected	MCL	MCLG	Units	Violation	Likely Source of contamination
2025	Atrazine	0.2	3	3	ppb	N	Runoff from herbicide used on row crops
2025	Metolachlor	0.3	700		ppb	N	Runoff from herbicide used on row crops

Atrazine Advisory: Some people who drink water containing atrazine well in excess of MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.

Inorganic Contaminants

Year	Contaminant	Level	MCL	MCLG	Units	Violation	Likely Source of contamination
2025	Fluoride	0.4	4	4	ppm	N	Erosion of natural deposits; water additive which promotes strong teeth,

2025	Nitrate (measured as Nitrogen)	0.37	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks, erosion of natural deposits. Nitrate in drinking water at levels above 10 mg/l is a health risk for infants of less than 6 months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.
2025	Barium	0.06	2	2	ppm	N	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits.

Year	Secondary Constituents	Level Detected			Units	Violation	Likely source of contamination
2025	Alkalinity	59			ppm	N	Erosion of natural deposits
2025	Aluminum	0.099			ppm	N	Erosion of natural deposits
2025	Calcium	31.1			ppm	N	Erosion of natural deposits
2025	Magnesium	2.82			ppm	N	Erosion of natural deposits
2025	Potassium	4.05			ppm	N	Erosion of natural deposits
2025	Sodium	26.8			ppm	N	Erosion of natural deposits
2025	Chloride	9.42			ppm	N	Erosion of natural deposits
2025	Texas Copper	0.001			ppm	N	Erosion of natural deposits
2025	Sulfate	67.9			ppm	N	Erosion of natural deposits
2025	Total Dissolved Solids	181			ppm	N	Erosion of natural deposits
2025	Manganese	0.002			ppm	N	Erosion of natural deposits
2025	Barium	0.06			ppm	N	Erosion of natural deposits.

2025	Nickel	0.001			ppm	N	Erosion of natural deposits.

Volatile Organic Compounds (VOCS)

Year	VOC	Average	Max Level	Units	Violation	Likely Source of contamination
2025	Chloroform	17.5	31.2	ppb	N	A disinfection by-product
2025	Bromochloroacetic Acid	2.9	4.0	ppb	N	A disinfection by-product
2025	Bromodichloromethane	6.8	11.7	ppb	N	A disinfection by-product
2025	Dibromochloromethane	1.3	2.7	ppb	N	A disinfection by-product
2025	Dichloroacetic Acid	10.6	19.2	ppb	N	A disinfection by-product
2025	Trichloroacetic Acid	6.6	9.8	ppb	N	A disinfection by-product
2025	Monobromoacetic Acid	0.0	1.4	ppb	N	A disinfection by-product.
2025	Monochloroacetic Acid	1.1	3.5	ppb	N	A disinfection by-product

Total Organic Carbon (TOC) - 2025

Source	Average Level Detected	Average Level Detected	Units	Likely Source of Contamination
Source Water	3.31	2.97	ppm	Naturally present in the environment
Treated Water	6.28	5.39	ppm	Naturally present in the environment
Removal Ratio		40% -51%	% removal	Removal ratio required > = 35%

Note: Total Organic Carbon has no health effects. The disinfectant can combine with TOC to form disinfection by-products. Disinfection is necessary to ensure that water does not have unacceptable levels of pathogens. Removal ratio is the percent of TOC removed by the treatment process. The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Violations 1

Violation Type	Violation Began	Violation Ended	Violation Explanation
Minor RTC	May 2025	July 3, 2025	Type 3A, Analyte: 8000 Revised Total Coliform Rule (RCR) Mon. Period: 05/01/2025-05/31/2025. Our system failed to collect the appropriate number of samples in May 2025 during our monthly sample testing. This resulted in a Monitoring Routine Violation (Minor RTC). In June 2025, all sample sites were collected. Our official date of compliance was July 3, 2025. Escherichia (E.coli) are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly and people with severely compromised immune systems.

TWDB Water Loss Audit

In the water loss audit survey submitted to the Texas Water Development Board for the time period of January 1, 2025 - December 31, 2025, our system lost an estimated 55,023,093 gallons of water.

Terms to Know

The following tables in this report use scientific terms and measures to label/clarify the amounts of different compounds. Below is some explanation of these terms and measures.

Level 1 Assessment	A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria were found.
Level 2 Assessment	A very detailed study of the water system to identify potential problems and determine (if possible) why an E.Coli maximum contaminant level (MCL) violation has occurred and/or why total coliform bacteria were found on multiple occasions.
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.
Maximum Contaminant Level (MCL)	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Residual Disinfectant Level Goal (MRDLG)	The level of a drinking water disinfectant below which there is no known expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum Residual Disinfectant Level (MRDL)	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants
Action Level (AL)	The concentration which, if exceeded, triggers treatment of other requirements which a water system must follow.
Treatment Technique (TT)	A required process intended to reduce the level of a contaminant in drinking water.

Abbreviations

Avg	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
MFL	Million fibers per liter (a measure of asbestos)
mrem	Millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units (a measure of turbidity)
pCi/L	Picocuries per liter (a measure of radioactivity)
ppb	Micrograms per liter (ug/L) or parts per billion
ppm	Milligrams per liter (mg/L) or parts per million

ppt	Nanograms per liter (ng/L) or parts per trillion
ppq	Picograms per liter (pg/L) or parts per quadrillion